

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

MONITORING REQUIREMENTS NOT MET FOR

CUNNINGHAM UTILITY DISTRICT

The Cunningham Utility District violated drinking water requirements during the second quarter of 2022. Even though this is **NOT** an emergency, you have the right to know what happened and what we are doing to correct this situation.

The Cunningham Utility District purchases its water from the Cunningham – East Montgomery Water Treatment Plant. Our Water Treatment Plant and the Cunningham Utility District are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether our drinking water meets health standards. We were required to sample for Atrazine between April 1, 2022 and June 30, 2022. Our sample was taken on March 23, 2022, which was out of the compliance period. Although the sample was taken early, the laboratory results showed that Atrazine **WAS NOT DETECTED** in your drinking water. Due to the testing being performed early, we cannot be sure of the quality of your drinking water during the following months.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant that we tested for out of the compliance period, how often we are supposed to sample for Atrazine, how many samples we are supposed to take, how many samples we took and when the sample should have been taken.

Contaminant	Required Sampling Frequency	Number of Samples Taken	When Samples Should Have Been Taken	When Samples Were Taken
Atrazine ¹	Yearly	1	April 1, 2022 - June 30, 2022	March 23, 2022

What is being done?

The management and staff of both the Cunningham – East Montgomery Water Treatment Plant and the Cunningham Utility District strive to monitor your drinking water as required. Therefore, a printed schedule of contaminants and their appropriate testing dates will be maintained.

For more information, please contact one of the following:

Danny Keaton	Plant Manager	CEMWTP	(931) 362-4105
John M. Atkins	General Manager	CUD	(931) 387-3387

This notice is being sent to you by the **Cunningham Utility District, PWSID # 0000167**

¹ **Atrazine** is a herbicide of the triazene class. It is used to prevent pre-emergence broadleaf weeds in crops such as corn. It is generally monitored because of agricultural run-off.